



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 5/11/09

Code 62-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3704.3		Page 669
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>E3704.3 Feeder neutral load. The feeder neutral load shall be the maximum unbalance of the load determined in accordance with this chapter. The maximum unbalanced load shall be the maximum net calculated load between the neutral and any one ungrounded conductor. For a feeder or service supplying electric ranges, wall-mounted ovens, counter-mounted cooking units and electric dryers, the maximum unbalanced load shall be considered as 70 percent of the load on the ungrounded conductors. <u>A further demand factor of 70 percent shall be permitted for that portion of the unbalanced load in excess of 200 amps.</u></p>		
REASON AND FISCAL IMPACT		
This text was extracted from the 2005 Indiana Residential Code.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		